

SWITCHBOARDS ON BUILDING AND CONSTRUCTION SITES



The ETU requires that all switchboards on building and construction sites (including site amenities), have a locked cover over the RCDs and circuit breaker.

This is to ensure that the reason for the fault is positively identified by the appropriately qualified personnel and rectified.

